

## PORTABLE APPLIANCE TESTING REPORT

Evelec Limited  
Old Wolverton Road  
Milton Keynes  
MK12 5FZ

Tel: 07709297709

**REPORT NO.:**

**1614**

**DATE OF TEST**

**7th April 2016**

Next Test Due: **7th April 2017**

**Client:**  
**Jon Evans**  
**Company:**  
**Easy DJ Hire**

ASSET ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	VISUAL INSPECT	TEST		Functional Check	Correct Fuse Rating	PASS or FAIL	COMMENTS
				EARTH	INSULATION				
				Ohms	Mohms				
1	IEC LEAD	MOBILE	GOOD	0.08	>299	YES	Correct	PASS	SATISFACTORY
2	IEC LEAD	MOBILE	GOOD	0.07	>299	YES	Correct	PASS	SATISFACTORY
3	IEC LEAD	MOBILE	GOOD	0.07	>299	YES	Correct	PASS	SATISFACTORY
4	IEC LEAD	MOBILE	GOOD	0.10	>299	YES	Correct	PASS	SATISFACTORY
5	IEC LEAD	MOBILE	GOOD	0.06	>299	YES	Correct	PASS	SATISFACTORY
6	IEC LEAD	MOBILE	GOOD	0.09	>299	YES	Correct	PASS	SATISFACTORY
7	IEC LEAD	MOBILE	GOOD	0.08	>299	YES	Correct	PASS	SATISFACTORY
8	EXTENSION LEAD 10M	MOBILE	GOOD	0.23	>299	YES	Correct	PASS	SATISFACTORY
9	EXTENSION LEAD 10M	MOBILE	GOOD	0.25	>299	YES	Correct	PASS	SATISFACTORY
10	EV ACTIVE SPEAKER	MOBILE	GOOD	0.15	>299	YES	Correct	PASS	SATISFACTORY
11	EV ACTIVE SPEAKER	MOBILE	GOOD	0.17	>299	YES	Correct	PASS	SATISFACTORY
12	CHAUVET INTIMIDATOR 350	MOBILE	GOOD	0.08	>299	YES	Correct	PASS	SATISFACTORY
13	CHAUVET INTIMIDATOR 350	MOBILE	GOOD	0.09	>299	YES	Correct	PASS	SATISFACTORY
14	CHAUVET INTIMIDATOR 350	MOBILE	GOOD	0.08	>299	YES	Correct	PASS	SATISFACTORY
15	CHAUVET INTIMIDATOR 350	MOBILE	GOOD	0.10	>299	YES	Correct	PASS	SATISFACTORY
16	1W ILDA LASOR	MOBILE	GOOD	0.03	>299	YES	Correct	PASS	SATISFACTORY
17	LED UPLIGHTER	MOBILE	GOOD	0.14	>299	YES	Correct	PASS	SATISFACTORY
18	LAPTOP PSU	MOBILE	GOOD	0.00	>299	YES	Correct	PASS	SATISFACTORY
19	LED UPLIGHTER	MOBILE	GOOD	0.09	>299	YES	Correct	PASS	SATISFACTORY



